

# WATER UTILITY OF GREATER TONOPAH - GARDEN CITY SYSTEM

## 2012 WATER QUALITY REPORT

This report contains information about the drinking water our utility provides to your home. Please take a moment to review this information and call us if you have any questions about our water service to you.

Water Utility of Greater Tonopah - A subsidiary of Global Water Resources (623) 518-4000

### Spanish (Espanol)

Este informe contiene información muy importante sobre la calidad de su agua para beber. Tradúscalo o hable con alguien que lo entienda bien.

### Is my water safe?

The Garden City water system, public water system number AZ04-07-037, which is part of the Water Utility of Greater Tonopah, is dedicated to providing

In 2012, your drinking water met all State and Federal drinking water standards.

customers with water that meets all Federal and State drinking water standards. Extensive tests have been conducted on your water to ensure your tap water is safe to drink. Unless otherwise indicated, this report is a snapshot of last year's water quality. Included in this report are details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. We are committed to providing you with information because informed customers are our best allies.

### Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised individuals such as those with cancer undergoing chemotherapy, or who have undergone organ transplants, or those with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

EPA / Centers for Disease Control and Prevention (CDC) provides guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial organisms. This information is available from the Federal Safe Drinking Water Hotline (800-426-4791) and on the CDC website at [www.cdc.gov](http://www.cdc.gov).

### Where does my water come from?

The Garden City system water is produced from a well located within its service area. The well is approximately 940 feet deep with a total production capacity of 30 gallons per minute.

Water from the well is chlorinated for disinfection and stored in two covered storage tanks with a total capacity of 23,500 gallons. A booster pump and a hydropneumatic tank maintain constant pressure throughout the distribution system.

### Source water assessment, and its availability

In 2004 the Arizona Department of Environmental Quality (ADEQ) completed a Source Water Assessment for the well used by Garden City. The assessment reviewed the hydrogeologic conditions and adjacent land uses that may pose a potential risk to the water sources. These risks include, but are not limited to, gas stations, landfills, dry cleaners, agriculture, wastewater treatment plants, and mining activities. Once ADEQ identified the adjacent land uses, they were ranked as to their potential to affect the water sources.

\*continued overleaf

### Water quality data table

Unless otherwise indicated, the table below lists all of the contaminants that we detected in the drinking water during the 2012 calendar year. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Substance	MCLG or MRDLG	MCL, TT or MRDL	Lowest Level	Highest Level	Compliance Achieved	Typical Source
<b>Disinfectants &amp; Disinfection By-Products</b> (There is convincing evidence that addition of a disinfectant is necessary for control of microbial organisms)						
Chlorine [as Cl <sub>2</sub> ] (ppm)	4	4	0.5	1.24	Yes	Water additive used to control microbes
Haloacetic Acids [HAA5] (ppb)	NA	60	NA	ND	Yes	By-product of drinking water disinfection
Total Trihalomethanes [TTHMs] (ppb)	NA	80	NA	10	Yes	By-product of drinking water disinfection
<b>Inorganic Chemicals</b>						
Arsenic (ppb) 2010 Data	0	10	NA	5.1	Yes	Erosion of natural deposits; runoff from glass and electronics production wastes
Barium (ppm) 2010 Data	2	2	NA	0.0047	Yes	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium (ppb) 2010 Data	100	100	NA	62	Yes	Discharge from steel and pulp mills; erosion of natural deposits
Fluoride (ppm) 2010 Data	4	4	NA	2.2	Yes	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate [measured as Nitrogen] (ppm)	10	10	NA	3.7	Yes	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits
<b>Unregulated Substances</b>						
Sodium (ppm) 2010 Data	NA	NA	NA	250	Yes	Naturally occurring mineral
<b>Microbial Organisms</b>						
Total Coliform (positive samples/month)	0	1	NA	0	Yes	Naturally present in the environment
<b>Radionuclides</b>						
Alpha emitters (pCi/L) 2010 Data	0	15	5.7	8.5	Yes	Erosion of natural deposits
<b>Lead and Copper</b>		<b>Action Level</b>		<b>Your Water</b>	<b>Compliance Achieved</b>	<b>Typical Source</b>
Copper - action level at consumer taps (ppm) 2010 Data		90% of homes tested must have copper levels less than 1.3 ppm		90% of the homes tested had copper levels less than 0.021 ppm	Yes	Corrosion of household plumbing systems; erosion of natural deposits
Lead - action level at consumer taps (ppb) 2010 Data		90% of homes tested must have lead levels less than 15 ppb		90% of the homes tested had lead levels below the detectable limits	Yes	Corrosion of household plumbing systems; erosion of natural deposits

Water conservation is everyone's responsibility. You can directly impact the availability of water in your community through judicious use of water by: irrigating at night, employing timers for irrigation systems, maximizing xeriscape, fixing leaky faucets, etc.

Please visit our website at [www.gwresources.com](http://www.gwresources.com) for additional information on water conservation practices.

The results of the assessment were that the well had a high risk of contamination due to adjacent land use.

A designation of high risk indicates there may be additional source water protection measures which can be implemented on the local level. **This designation does not imply that the source water is contaminated nor does it mean that**

**contamination is imminent.** Rather, it simply states that land use activities or hydrogeologic conditions exist that make the source water susceptible to possible future contamination. The system is routinely monitored for potential contamination. **To date, no contamination has been discovered.** The water is protected by well construction and system operations and management. Residents can help protect the water by taking hazardous household chemicals to hazardous material collection days and limiting pesticide and fertilizer use.

The complete assessment is available for inspection at ADEQ, 1110 W. Washington St., Phoenix, Arizona 85007, between the hours of 8:00 a.m. and 5:00 p.m. Electronic copies are available from ADEQ. For more information, call ADEQ's Source Water Assessment and Protection Unit at 602-771-4644 or visit their website at [www.azdeq.gov](http://www.azdeq.gov).

### General information about drinking water

To ensure your tap water is safe to drink, the EPA issues regulations that limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that water poses a health risk. More information about these contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

### For more information please contact:

Global Water, Water Utility of Greater Tonopah, Garden City, PWS AZ04-07-037  
 Address: 21410 N. 19th Ave., Suite 201, Phoenix, AZ 85027  
 P: 623-518-4000 F: 623-580-9659 [www.gwresources.com](http://www.gwresources.com)

Sources of drinking water (both tap water and bottled water) include rivers, lakes, reservoirs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive materials and can pick up contaminants resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include the following:

- Microbial organisms including viruses, bacteria or parasites (such as Cryptosporidium or Giardia), which may come from agricultural or livestock operations and wildlife;
- Inorganic chemicals such as salts and metals which can be naturally occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming;
- Pesticides and herbicides which may come from a variety of sources such as agriculture, storm water runoff and residential uses;
- Organic chemicals including synthetic and volatile organic compounds, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff and septic tanks;
- Radioactive chemicals which occur naturally or result from oil and gas production and mining activities.

### Additional information for fluoride

This is an alert about your drinking water and a cosmetic dental problem that might affect children under nine years of age. At low levels, fluoride can help prevent cavities, but children drinking water containing more than 2 ppm of fluoride may develop cosmetic discoloration of their permanent teeth (dental fluorosis). Garden City water has a level of 2.2 ppm.

Dental fluorosis, in its moderate or severe forms, may result in a brown staining and/or pitting of the permanent teeth. This problem occurs only in developing teeth, before they erupt from the gums. Children under nine should be provided with alternative sources of drinking water or water that has been treated to remove the fluoride to avoid the possibility of staining and pitting of their permanent teeth. You may also want to contact your dentist about proper use by young children of fluoride-containing products. Older children and adults may safely drink the water.

### Additional information for fluoride (continued)

Drinking water containing more than 4 ppm of fluoride (the U.S. Environmental Protection Agency's drinking water standard) can increase your risk of developing bone disease. Your drinking water **does not** contain more than 4 ppm of fluoride, but we're required to notify you when the fluoride levels in your drinking water exceeds 2 ppm.

Some home water treatment units are also available to remove fluoride from drinking water. To learn more about available home water treatment units, you may call NSF International at 1-800-NSF-MARK.

### Additional information for arsenic

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Unit descriptions	
ppm:	parts per million; milligrams per liter (mg/L)
ppb:	parts per billion; micrograms per liter (ug/L)
pCi/L:	picouries per liter (a measure of radioactivity)
Positive samples/month:	number of samples taken monthly that were found to be positive
NA:	not applicable
ND:	not detected

Important drinking water definitions	
MCLG:	Maximum Contaminant Level Goal - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.
MCL:	Maximum Contaminant Level - The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.
TT:	Treatment Technique - A required process intended to reduce the level of a contaminant in drinking water.
AL:	Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variations and Exemptions:	State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG:	Maximum Residual Disinfectant Level Goal - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL:	Maximum Residual Disinfectant Level - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

For over a hundred ways to save water, visit: [www.wateruseitwisely.com](http://www.wateruseitwisely.com)

